

# IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

## CB TEST CERTIFICATE

Product

**Portable socket-outlet**

Name and address of the applicant

**LEGRAND FRANCE**  
128 AVENUE DU MARECHAL DE LATTRE DE TASSIGNY  
87045 LIMOGES CEDEX  
FRANCE

Name and address of the manufacturer

**LEGRAND FRANCE**  
128 AVENUE DU MARECHAL DE LATTRE DE TASSIGNY  
87045 LIMOGES CEDEX  
FRANCE

Name and address of the factory

**LEGRAND FRANCE SILLE LE GUILLAUME**  
80 ROUTE D'EVIRON  
72140 SILLE LE GUILLAUME  
FRANCE

Note: When more than one factory, please report on page 2

☐ Additional Information on page 2

Ratings and principal characteristics

See Annex

Trademark / Brand (if any)

**LEGRAND**

Customer's Testing Facility (CTF) Stage used

/

Model / Type Ref.

0 505 75  
0 908 20

Additional information (if necessary may also be reported on page 2)

Supersedes CBTC 60046752A dated 10/07/2006. Update further to the evolution of the standard(s)

☐ Additional Information on page 2

A sample of the product was tested and found to be in conformity with

IEC 60884-1:2002(ed.3) +A1:2006 +A2:2013

As shown in the Test Report Ref. No. which forms part of this Certificate

169825-758400

This CB Test Certificate is issued by the National Certification Body



LCIE – Laboratoire Central des Industries Electriques  
33, avenue du Général Leclerc – BP8  
FR 92 266 Fontenay aux Roses Cedex  
[www.lcie.fr](http://www.lcie.fr)

Date: 03/06/2021



LABORATOIRE CENTRAL DES  
INDUSTRIES ELECTRIQUES  
S.A.S au capital de 15.745.984 €  
RCS Nanterre B 488 363 174  
33 avenue du Général Leclerc  
F - 92266 FONTENAY AUX ROSES

*Signature*  
**Julien Gauthier**  
Certification Officer

## ANNEX

References, ratings and main characteristics:

References	Nb of sockets outlets	Current	Voltage	Load	Degree of protection
0 505 75	2	16A	230V~	3680 W	IP 44
0 908 20	2	16A	230V~	3680 W	IP 44

Standard Sheet	V (CEE7)
Rated current (A)	16A
Rated load (W)	see table
Rated voltage (V)	250 V~
Household voltage (V)	230 V~
Degree of protection	IP44
Provision for earthing	with earthing contact
Method of connecting the cable	rewirable
Type of terminals	screw-type
Type of connection	crimped
Colour	black
Pins	solid
<b>socles / socket-outlets</b>	
Number of socket-outlets	2
Degree of protection against electric shock	increased protection
Existence of shutters	with shutters
Method of application - mounting	portable type



LCIE – Laboratoire Central des Industries Electriques  
33, avenue du Général Leclerc – BP8  
FR 92 266 Fontenay aux Roses Cedex  
[www.lcie.fr](http://www.lcie.fr)



LABORATOIRE CENTRAL DES  
INDUSTRIES ELECTRIQUES  
S.A.S au capital de 15.745.984 €  
RCS Nanterre B 408 363 174  
33 avenue du Général Leclerc  
F - 92266 FONTENAY AUX ROSES

Signature: *Julien Gauthier*  
Certification Officer

Date: 03/06/2021